

**DECLARATION OF PERFORMANCE** (Number DoP04-UK)

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

1. **Unique identification code of the product-type:** Firebreak 66 Intumescent Pressure Sealant
2. **Intended use(es):**  
Fire protection and/or fire protection performance, 0843-UKTA-24/0007, EAD 350454-00-1104, September 2017
3. **Manufacturer:**  
Neutron Fire Technologies Ltd., Shire Hall, Quay Street, Lostwithiel, Cornwall PL22 OBS, U.K.
4. **Not applicable**
5. **System(s) of AVCP: System 1**
6. **European Assessment Documents:** EAD 350454-00-1104, September 2017  
**UK Technical Assessment:** 0843-UKTA-24/0007  
**Technical Approval Body:** UL International (UK) Ltd  
**Approved Body:** 0843
7. **Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	No performance determined
Resistance to Fire	EN 13501-2, 0843-UKTA-24/0007
Air Permeability	No performance determined
Dangerous Substances	0843-UKTA-24/0007, Section 1.3
Protection Against Noise	No performance determined
Service and Durability	Y <sub>2(-50C/70oC)</sub> : intended for use in internal or external sheltered conditions with high or other humidity classes, including temperatures below 0 °C but without exposure to rain or u.v.
Other	Not applicable or no performance determined

8. **Appropriate Technical Documentation and/or Specific Technical Documentation:**  
0843-UKTA-24/0007. Online copy of the Declaration of Performance:  
[www.neutronfire.com](http://www.neutronfire.com)

Signed for and on behalf of: Neutron Fire Technologies Ltd



Luke O'Keeffe, Managing Director