

DECLARATION OF PERFORMANCE (Number DoP06-UK)

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

1. **Unique identification code of the product-type:** Firebreak Batt
2. **Intended use(es):**
Fire protection and/or fire protection performance, 0843-UKTA-24/0009, EAD 350454-00-1104, September 2017
3. **Manufacturer:**
Neutron Fire Technologies Ltd., Shire Hall, Quay Street, Lostwithiel, Cornwall PL22 OBS, U.K.
4. **Not applicable**
5. **System(s) of AVCP: System 1**
6. **European Assessment Documents:** EAD 350454-00-1104, September 2017
UK Technical Assessment: 0843-UKTA-24/0009
Technical Approval Body: UL International (UK) Ltd
Approved Body: 0843
7. **Declared performance:**

| Essential Characteristics | Performance/Harmonised technical specification |
|---------------------------|---|
| Reaction to Fire | Not determined |
| Resistance to Fire | EN 13501-2, 0843-UKTA-24/0009 |
| Air Permeability | No performance determined |
| Dangerous Substances | 0843-UKTA-24/0009, Section 1.3 |
| Protection Against Noise | No performance determined |
| Service and Durability | Z ₁ : intended for use in internal conditions with high humidity excluding temperatures below 0 °C |
| Other | Not applicable or no performance determined |

8. **Appropriate Technical Documentation and/or Specific Technical Documentation:**
0843-UKTA-24/0009. Online copy of the Declaration of Performance:
www.neutronfire.com

Signed for and on behalf of: Neutron Fire Technologies Ltd



Luke O'Keeffe, Managing Director