

DECLARATION OF PERFORMANCE (Number DoP08-UK)

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

- 1. Unique identification code of the product-type:** Firebreak FX Series Pipe Collar
- 2. Intended use(es):**
Fire protection and/or fire protection performance, 0843-UKTA-24/0010, EAD 350454-00-1104, September 2017
- 3. Manufacturer:**
Neutron Fire Technologies Ltd., Shire Hall, Quay Street, Lostwithiel, Cornwall PL22 OBS, U.K.
- 4. Not applicable**
- 5. System(s) of AVCP: System 1**
- 6. European Assessment Documents:** EAD 350454-00-1104, September 2017
UK Technical Assessment: 0843-UKTA-24/0010
Technical Approval Body: UL International (UK) Ltd
Approved Body: 0843
- 7. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	FX300/FX500 Class E
Resistance to Fire	EN 13501-2, 0843-UKTA-24/0010
Air Permeability	No performance determined
Dangerous Substances	0843-UKTA-24/0010, Section 1.3
Protection Against Noise	No performance determined
Service and Durability	Y ₂ : intended for use at temperatures below 0 °C but without exposure to rain or u.v.
Other	Not applicable or no performance determined

- 8. Appropriate Technical Documentation and/or Specific Technical Documentation:**
0843-UKTA-24/0010. Online copy of the Declaration of Performance:
www.neutronfire.com

Signed for and on behalf of: Neutron Fire Technologies Ltd



Luke O'Keeffe, Managing Director