

Declaration of Performance

According to Annex III of the Regulation (EU) No. 305/2011



Neutron Fire Technologies Ltd
Shire Hall, Lostwithiel PL22 0BS U.K.

21

2821-CPR-0117

Firebreak 22 - 2024022207

www.neutronfire.com/data

EN 1366-3 & EN 1366-4

ETA 21/0213 & ETA 21/0222

EAD 350454-00-1104, September 2017 & EAD350141-00-1106, September 2017

Firebreak 22 is used to seal around cables and metallic pipes to form a penetrate seal to reinstate the fire performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions, where they abut or include gaps

Essential Characteristic	Performance
Safety in Case of Fire	
Reaction to fire	No performance assessed
Resistance to fire	See ETA 21/0213 & ETA 21/0222 - Annex A
Hygiene, Health and Environment	
Air permeability (EN 1026:2000)	No performance assessed
Release of dangerous substances	Use categories: IA1, S/W3. Declaration of manufacturer
Safety in Use	
Mechanical resistance and stability	No performance assessed
Resistance to impact/movement	No performance assessed
Adhesion	No performance assessed
Protection against Noise	
Airborne sound insulation	No performance assessed
Energy, Economy and Heat Retention	
Thermal properties	No performance assessed
Water vapour permeability	No performance assessed
General aspects relating to fitness for use	
Service and durability	Z ₁